BE REFER TO TECHNICAL SPECIFICATIONS
2.4 STRUCTURAL
2.4.1 DESCRIPTION
2.4.1.1 FORT WITH TOWER
2.4.1.1.1 Intervention Plan

REINFORCED SLAB REQUIREMENTS

1. EXECUTION OF REINFORCEMENT WITH WELDED MESH Ø8 15x15 cm, ANCHORING TO MASONRY BY METAL ROD Ø12 EVERY 60 cm
2. CONCRETING OF RCK 300 CONCRETE THICKNESS ≈ 6 cm

02 FORT - REINFORCED SLAB STRATIGRAFY

0 0,2 1 m

DRAWING TITLE
FORT: STRUCTURAL DESIGN

DRAWING N°
MNE.SD.01

AXUM project & building Co. Ltd. projektovanje,inženjering,izvođenje	II Dalmatinske P+5 85320 TIVAT, Montenegro		ARCHITECTURAL Phase	
investitor:	MINISTRY OF SUSTAINABLE DEVELOPMENT AND TOURISM MINISTRY OF CULTURE			
object:	Besac Fortress, NP " SCUTARI LAKE", cadastral n° 24, KO Boljevići, Municipality of Bar			
project:	MAIN PROJECT - Rehabilitation			
Lead Designer:	Ivan STIPANIĆ, Arch			
Architectural Lead Designer:	Ivan STIPANIĆ, Arch			
Collaborators:	Viktor NASTOSKI, Arch Svetlana PANIĆ, Arch			
Title:	FORT WITH TOWERS-STRUCTURAL SPECIFICATIONS			
Project Code: GP 04-09/11	date: IX-2011	scale: 1:20	list:	09